

1313.5 Exterior lighting. No 120 volt incandescent or mercury vapor lighting sources shall be used for exterior building lighting. The total exterior lighting power allowance for all exterior building applications is the sum of the base site allowance plus the individual allowances for areas that are designated on the building plans to be illuminated and are permitted in Table 1313.5 (1) for the applicable *Lighting Zone*. Trade-offs are allowed only among exterior lighting applications listed in Table 1313.5 (1), Tradable Surfaces section. The lighting zone for building exterior is determined from Table 1313.5 (2) unless otherwise specified by the local jurisdiction.

Exceptions:

1. Any exterior lighting power allowance and luminaire requirements that are regulated through local ordinance.
2. Lighting used in or around swimming pools, water features, or other locations subject to the requirements of Article 680 of the *National Electrical Code*.