

Table 1312.2.1 (1)

Envelope Prescriptive Path, Other Buildings - Climate Zone 1

Walls	Max. Glazing Fraction	Max. U-Factor	Min. Insulation R-Value
Masonry, with integral insulation	15%	0.25	--
Masonry or concrete, with interior insulation - steel frame	30%	0.104	15
Masonry or concrete, with interior insulation - wood frame	30%	0.104	15
Masonry or concrete, with continuous exterior insulation	30%	0.113	9.5 c.i.

Table 1312.3.1 (2)

Envelope Prescriptive Path, Other Buildings - Climate Zone 2

Walls	Max. Glazing Fraction	Max. U-Factor	Min. Insulation R-Value
Masonry, with integral insulation	10%	0.25	--
Masonry or concrete, with interior insulation - steel frame	30%	0.090	21
Masonry or concrete, with interior insulation - wood frame	30%	0.090	21
Masonry or concrete, with continuous exterior insulation	30%	0.113	11.4 c.i.