

Proposed Language by Staff
(2009 Model code changes – Suggested new Oregon amendment)

Proposal 3:

401.2 Ventilation required. Every occupied space shall be ventilated by natural means in accordance with Chapter 12 of the *Building Code* or by mechanical means in accordance with Section 403.

Exception: Rooms within a private dwelling which contains a bathtub, shower or spa facility shall be provided with mechanical ventilation in accordance with the provisions of Table 403.3.