

Proposed Language by Staff
(2009 Model code changes – Suggested new Oregon amendment)

Proposal 6:

510.5.7 Ducts. Hazardous exhaust duct systems shall extend directly to the exterior of the building and shall not extend into or through ducts and plenums.

510.5.8 Motors and fans. Motors and fans used in conjunction with hazardous exhaust systems shall be in accordance Section 503.

Reason: This modification was submitted during the 2007 mid-cycle code change process. BCD addressed the issue with an Interpretive Ruling instead of adopting it early. By approving this road map code change the newly created interpretation can be deleted.