

Recommendations of the
STRUCTURAL ENGINEERS ASSOCIATION of OREGON

Existing OSSC amendments not yet acted upon by OSSC Code Change Committee:

| ITEM | DESCRIPTION | REC. | SUMMARY |
|----------|------------------------------|----------|--|
| EA07-18 | 1802.1 & Table 1802.1 | Maintain | Existing DOGAMI requirement. |
| EA07-18 | 1802.2 Exception | Maintain | Expands scope of exception to include seismic zones D, E & F. |
| EA07-18 | 1802.2.7(1) | Maintain | Allows seismic lateral pressures to be based on one-half of the peak horizontal acceleration. |
| EA07-18 | 1802.4.2 | Maintain | Based on ORS 455.447, Seismic Site Hazard Investigation/Report |
| EA07-18 | 1802.7 | Maintain | Based on ORS 455.447, Seismic Site Hazard Investigation/Report |
| EA07-18 | 1802.8 | Maintain | Based on ORS 455.447, Seismic Site Hazard Investigation/Report |
| EA07-18 | 1802.9 | Maintain | Based on ORS 455.447, Seismic Site Hazard Investigation/Report |
| EA07-18 | 1803.7 | Maintain | Foundation Drainage. Not captured in 2009 IBC. |
| EA07-18 | 1805.4.2.7 | Maintain | Grounding of foundation rebar. Not captured in 2009 IBC. |
| EA07-18 | 1806.1 | Delete | Captured in section 1807.2.3 of the 2009 IBC. |
| EA07-18 | 1808.2.8.5 (2) | Maintain | Allows BO to approve other analysis for determining allowable working uplift for pier and pile loads. |
| EA07- 21 | 2104.6 | Maintain | Requires embedded bolts in masonry to be grouted in place. Not captured in 2009 IBC. |
| EA07- 21 | 2104.7 | Maintain | Addresses cleanouts in masonry. Not captured in 2009 IBC. |
| EA07- 21 | 2106.1 | Maintain | Allows exception for special reinforced masonry shear walls where the masonry resists the calculated shear without reinforcement. |
| EA07- 23 | 2304.11.2.2 | Maintain | Wood less than 6 inches from exposed earth must be naturally durable or preservative-treated. Consistent with Residential Code. 2009 IBC sets the measurement at 8 inches. |
| EA07- 23 | 2308.3.2 | Pending | Defer to OSSC 10-44? |
| EA07- 23 | Figures 2308.3.2 (1) and (2) | Pending | Defer to OSSC 10-44? |
| EA07-23 | 2308.12.6 | Pending | Captured in 2009 IBC? |