

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
SUBSTANTIAL REQUIREMENT CHANGES IN 2009 MODEL CODE					
311.2	Changes Occupancy Classification of aircraft hangars without maintenance or overhaul from an "S-2" to an "S-1"	N/A	Approved 5-12-09		
403.2.3	Requires specific impact rating for materials used in exit enclosures and elevator hoistways in High-rise structures	N/A	Approved 5-12-09		
403.3.2	Requires two separate connections to the water main for fire pump supply in High-rise structures.	N/A	Approved 5-26-09		
403.4.6	Requires natural or mechanical ability to remove smoke from each floor in High-rise structures	N/A	Approved 5-26-09		
403.6.1	Requires the installation of an additional elevator for fire service use in High-rise structures with occupied floor more than 120'.	N/A	Approved 5-26-09		
412.4.6.1	Requires fire suppression designed to Group 1 or Group 2 for group 3 hangars based on hazard specific criteria	N/A	Approved 5-12-09		
419	New provisions for "Live/Work Units"	N/A	Approved 5-12-09		7-22-09 Approved as amended by coordination changes to 419.7, 1106.1.10 & 1110.1
422	New provisions Ambulatory Health Care Facilities	N/A	Approved 5-12-09		
423	New provisions for Storm Shelters	N/A	Approved 5-12-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
Table 503	Significant reduction in allowable stories for certain Occupancy and construction types.	N/A	Approved 5-12-09		
703.6	Requires permanent identification of fire rated assemblies.	N/A	Approved 5-12-09		
705.5	Increases the fire separation distance required to look at exposure from the inside of the structure.	N/A	Approved 5-12-09		
903.2.2	Requires fire sprinklers in certain Group B ambulatory health care facilities.	N/A	Approved 5-12-09		
903.3.2.3	Reduces fire area trigger for sprinklers in Group E occupancies from 20,000 sq. ft. to 12,000 sq. ft.	N/A	Approved 5-12-09		
903.2.7	Requires sprinklers in all Group M occupancies that display or sell upholstered furniture. (903.2.7 Item #4)	N/A	<i>Disapproved</i> 5-26-09		<i>Committee disapproved this significant model code change - item 4 will be deleted</i>
903.2.9.1 #4	Requires sprinklers in Group S-1 fire areas over 5,000 used for repair of commercial trucks or busses.	N/A	Approved 5-12-09		
907.2.2.1	Requires smoke detection system in Group B ambulatory health care facilities.	N/A	Approved 5-12-09		
915	Requires emergency responder radio coverage in all new buildings.	N/A	Approved 7-22-09		See OSSC10-48 for Oregon modifications
1024	New section requiring luminous egress path markings in certain High-rise structures	N/A	Approved 5-26-09		
1405.3	New provisions for Vapor retarders	N/A	Approved 5-12-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
1609.6	New section providing an alternative method for determining wind effects on a structure.	N/A	Approved 7-22-09		
1614	New section with specific structural integrity requirements for High-rise structures.	N/A	Tabled 5-12-09		Tabled 7-22-09- SEAO to provide a recommendation on these new provisions
3007	New Section containing provisions for Fire Service Access Elevators	N/A	Approved 5-26-09		
3008	New Section containing provisions for Occupant Evacuation Elevators	N/A	Approved 5-26-09		
EDITORIAL AND NON-SUBSTANTATIVE REQUIREMENT CHANGES IN 2009 MODEL CODE					
Chapter 1	Administration	N/A	Tabled 5-26-09		Tabled 7-22-09 Staff to provide BCD recommendations for Chapter 1
Chapter 2	Definitions	N/A	Approved 5-26-09		
Chapter 3	Use and Occupancy Classification	N/A	Approved 5-26-09		
Chapter 4	Special Detailed Requirements Based on Use and Occupancy	N/A	Approved 5-26-09		7-22-09: 408 provisions approved as amended per staff revisions dated 7-18-09
Chapter 5	General Building Heights and Areas	N/A	Approved 5-26-09		
Chapter 6	Types of Construction	N/A	Approved 5-26-09		
Chapter 7	Fire-Resistance-Rated Construction	N/A	Approved 5-26-09		Tabled 7-22-09 705.2 - Staff to work with OBOA on potential fix
Chapter 8	Interior Finishes	N/A	Approved 5-26-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
Chapter 9	Fire Protection Systems	N/A	Approved 5-26-09		
Chapter 10	Means of Egress	N/A	Approved 6-10-09		
Chapter 11	Accessibility	N/A	<i>Disapproved</i> 6-10-09		
Chapter 12	Interior Environment	N/A	Approved 6-10-09		
Chapter 13	Energy Efficiency	N/A	<i>Disapproved</i> 6-10-09		
Chapter 14	Exterior Walls	N/A	Approved 6-10-09		
Chapter 15	Roof Assemblies and Rooftop Structures	N/A	Approved 6-10-09		
Chapter 16	Structural Design	N/A	Approved 6-10-09		
Chapter 17	Structural Tests and Special Inspection	N/A	Approved 7-9-09		
Chapter 18	Soils and Foundations	N/A	Tabled 6-10-09		Tabled 7-22-09 SEAO to provide a recommendation on these new provisions
Chapter 19	Concrete	N/A	Approved 6-10-09		
Chapter 20	Aluminum	N/A	Approved 6-10-09		
Chapter 21	Masonry	N/A	Approved 6-10-09		
Chapter 22	Steel	N/A	Approved 6-10-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
Chapter 23	Wood	N/A	Approved 6-10-09		
Chapter 24	Glass and Glazing	N/A	Approved 6-10-09		
Chapter 25	Gypsum Board and Plaster	N/A	Approved 6-10-09		
Chapter 26	Plastic	N/A	Approved 6-10-09		
Chapter 27	electrical	N/A	Approved 6-10-09		
Chapter 28	Mechanical Systems	N/A	Approved 6-10-09		
Chapter 29	Plumbing Systems	N/A	<i>Disapproved</i> 6-10-09		
Chapter 30	Elevators and Conveying Systems	N/A	Approved 6-10-09		
Chapter 31	Special Construction	N/A	Approved 6-10-09		
Chapter 32	Encroachments into the Public Right-Of-Way	N/A	Approved 6-10-09		
Chapter 33	Safeguards During Construction	N/A	Approved 6-10-09		
Chapter 34	Existing Structures	N/A	Approved 6-10-09		
Chapter 35	Referenced Standards	N/A	Approved 6-10-09		
Appendix A	Employee Qualifications	N/A	<i>Disapproved</i> 6-10-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
Appendix B	Board of Appeals	N/A	<i>Disapproved 6-10-09</i>		
Appendix C	Group U - Agricultural Buildings	N/A	Approved 6-10-09		
Appendix D	Fire Districts	N/A	<i>Disapproved 6-10-09</i>		
Appendix E	Supplementary Accessibility Requirements	N/A	<i>Disapproved 6-10-09</i>		
Appendix F	Rodent Proofing	N/A	<i>Disapproved 6-10-09</i>		
Appendix G	Flood-Resistant Construction	N/A	<i>Disapproved 6-10-09</i>		
Appendix H	Signs	N/A	<i>Disapproved 6-10-09</i>		
Appendix I	Patio Covers	N/A	Approved 6-10-09		
Appendix J	Grading	N/A	<i>Disapproved 6-10-09</i>		
Appendix K	ICC Electrical Code	N/A	<i>Disapproved 6-10-09</i>		

EXISTING OREGON AMENDMENTS

EA07-01	CHAPTER 1 - Administrative	N/A	Tabled 7-22-09		Tabled: Staff to provide BCD recommendations for Chapter 1
EA07-02	CHAPTER 2 - Definitions	N/A	Approved 6-10-09		7-22-09: 408 provisions approved as amended per staff revisions dated 7-18-09
EA07-03	CHAPTER 3 - Use and Occupancy Classification	N/A	Approved 6-10-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
EA07-04	CHAPTER 4 - Special Detailed Requirements	N/A	Approved 6-10-09		7-22-09: 408 provisions approved as amended per staff revisions dated 7-18-09
EA07-05	CHAPTER 5 - General Building Heights and Areas	N/A	Approved 7-9-09		Retain 506.3
EA07-06	CHAPTER 6 - Types of Construction (none)	N/A	N/A	N/A	No existing Oregon amendments
EA07-07	CHAPTER 7 - Fire-Resistance-Rated Construction	N/A	N/A	N/A	No existing Oregon amendments
EA07-08	CHAPTER 8 - Interior Finishes (none)	N/A	N/A	N/A	No existing Oregon amendments
EA07-09	CHAPTER 9 - Fire Protection Systems	N/A	Approved 7-9-09		Retain all except 903.2.10 enclosed parking provisions
EA07-10	CHAPTER 10 - Means of Egress	N/A	Approved 7-9-09		7-22-09: Delete OR amendment 1008.1.2. Retain 1009.11.1 Roof Access
EA07-11	CHAPTER 11 - Accessibility	N/A	Approved 7-9-09		
EA07-12	CHAPTER 12 - Interior Environment	N/A	Approved 7-9-09		
EA07-13	CHAPTER 13 - Energy Efficiency	N/A	N/A		Commercial Energy Code Committee is reviewing this Chapter
EA07-14	CHAPTER 14 - Exterior Walls	N/A	Approved 7-9-09		
EA07-15	CHAPTER 15 - Roof Assemblies and Rooftop Structures	N/A	Approved 7-9-09		
EA07-16	CHAPTER 16 - Structural Design	N/A	Approved 7-9-09		7-22-09: Figure 1609 - Wind speeds updated to coordinate with revised calcs. Delete all references to 1998 OSSC wind speed methodology.

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
EA07-17	CHAPTER 17 - Structural Tests and Special Inspections	N/A	Approved 7-9-09		
EA07-18	CHAPTER 18 - Soils and Foundations	N/A	Approved 7-22-09		
EA07-19	CHAPTER 19 - Concrete	N/A	N/A	N/A	No existing Oregon amendments
EA07-20	CHAPTER 20 - Aluminum	N/A	N/A	N/A	No existing Oregon amendments
EA07-21	CHAPTER 21 - Masonry	N/A	Approved 7-22-09		
EA07-22	CHAPTER 22 - Steel	N/A	N/A	N/A	No existing Oregon amendments
EA07-23	CHAPTER 23 - Wood	N/A	Approved 7-22-09		TABLED: 2308.3.2, Fig 2308.3.2(1) & (2) & 2308.12.6 - SEAO to provide recommendations
EA07-24	CHAPTER 24 - Glass and Glazing	N/A	N/A	N/A	No existing Oregon amendments
EA07-25	CHAPTER 25 - Gypsum Board and Plaster	N/A	N/A	N/A	No existing Oregon amendments
EA07-26	CHAPTER 26 - Plastic	N/A	N/A	N/A	No existing Oregon amendments
EA07-27	CHAPTER 27 - Electrical	N/A	N/A	N/A	No existing Oregon amendments
EA07-28	CHAPTER 28 - Mechanical Systems	N/A	N/A	N/A	No existing Oregon amendments
EA07-29	CHAPTER 29 - Plumbing Systems	N/A	Approved 7-22-09		
EA07-30	CHAPTER 30 - Elevators and Conveying Sys.	N/A	Approved 7-22-09		
EA07-31	CHAPTER 31 - Special Construction	N/A	Approved 7-22-09		
EA07-32	CHAPTER 32- Encroachments	N/A	Approved 7-22-09		
EA07-33	CHAPTER 33 - Safeguards During Construction	N/A	N/A	N/A	No existing Oregon amendments

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
EA07-34	CHAPTER 34 - Existing Structures	N/A	Tabled 7-22-09		Tabled - At request of BOMA
EA07-35	CHAPTER 35 - Referenced Standards	N/A	Approved 7-22-09		Retain NFPA 307-06 Piers, Wharves
EA07-36	APPENDIX A - Employee Qualifications (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-37	APPENDIX B - Board of Appeals (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-38	APPENDIX C - Group U Agricultural Buildings	N/A	Approved 7-22-09		
EA07-39	APPENDIX D - Fire Districts (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-40	APPENDIX E - Supplementary Accessibility Requirements (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-41	APPENDIX F - Rodent Proofing (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-42	APPENDIX G - Flood-Resistant Construction (Not adopted by the State of Oregon but may be adopted by local municipalities)	N/A	Approved 7-22-09		
EA07-43	APPENDIX H - Signs (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-44	APPENDIX I - Patio Covers (Adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-45	APPENDIX J - Grading (Adopted by the State of Oregon for optional use in municipalities)	N/A	Approved 7-22-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
EA07-46	APPENDIX K - ICC Electric code Administrative provisions (Not adopted by the State of Oregon)	N/A	Approved 7-22-09		
EA07-47	APPENDIX L - Wildfire Hazard Mitigation (Adopted by the State of Oregon for optional use in municipalities)	N/A	Approved 7-22-09		
EA07-48	APPENDIX SR - Group SR Special Residence Occ. (Adopted by the State of Oregon)	N/A	Approved 7-22-09		
NEW AMENDMENT PROPOSALS (PUBLIC)					
http://www.bcd.oregon.gov/committees/10ossc/proposals.html					
OSSC10-01	Section 101.1 Title	Gary Armstrong	<i>Disapproved</i> 6-25-09		
OSSC10-02	Section 910 Adds testing requirement	Architectural Specialties Inc.	<i>Disapproved</i> 6-25-09		
OSSC10-03	Section 1704.12.5 Modifies test requirements for spray applied fire proofing	Carlson Testing Inc.	Tabled 6-25-09 7-22-09		
OSSC10-04	Section 1501.2 Adds rooftop fall protection anchorage requirements	OR-OSHA	Tabled 5-26-09		Tabled 7-22-09 for further revisions by proponent.
OSSC10-05	Section 1613.7.6 Modifies size of ceiling requiring horizontal restraint	N.W. Wall and Ceiling Bureau	Approved 6-25-09		
OSSC10-06	Section 1008.1.9.3 Amends criteria for allowing key-operated locking devices	Hillsboro Fire Department	<i>Disapproved</i> 6-25-09		
OSSC10-07	Section 903.2.7 Amends sprinkler threshold for Group M Occupancies	OBOA	<i>Withdrawn</i> 5-26-09		<i>Proponent withdrew proposal 5-26-09</i>
OSSC10-08	Section 903.3.1.2.1 Amends balcony and deck sprinkler requirement	OBOA	Approved 6-25-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
OSSC10-09	Section 9.6.1 Adds section addressing fire extinguishers in existing buildings	OBOA	<i>Withdrawn 6-25-09</i>		<i>Proponent withdrew proposal 6-25-09</i>
OSSC10-10	Adds Section 2305.4 modifying shear wall capacity calculation of AF&PA SWPWS	SEAO	Approved 7-09-09		
OSSC10-11	Section 1613.7 modifies existing amendments to ASCE 7	SEAO	Approved 7-09-09		
OSSC10-12	Section 1613.7 modifies existing amendments to ASCE 7	SEAO	Approved 7-09-09		
OSSC10-13	Section 1613.7 modifies existing amendments to ASCE 7	SEAO	Approved 7-09-09		
OSSC10-14	Section 1608.2 Changes base document for determining snow loads	SEAO	Approved 7-09-09		
OSSC10-15	Table 1607.1 Adds Foot bridge load values to the table	SEAO	Approved as modified 7-9-09		
OSSC10-16	1608.1 Changes base document for snow load design	SEAO	Approved 7-09-09		
OSSC10-17	Table 1607.1 Deletes specific reference to habitable attic from load table	SEAO	<i>Withdrawn 7-9-09</i>		<i>Proponent withdrew proposal 7-9-09</i>
OSSC10-18	Section 603.1 Exceptions. Adds exception for certain use of fire retardant treated wood	City of Portland	<i>Disapproved 6-25-09</i>		
OSSC10-19	Section 705.5 Adds continuity language for fire rated exterior walls	City of Portland	<i>Disapproved 6-25-09</i>		
OSSC10-20	Section 704.8 Specifies spacing of allowable openings in exterior walls	City of Portland	<i>Disapproved 6-25-09</i>		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
OSSC10-21	RESERVED	N/A	N/A	N/A	N/A
OSSC10-22	Section 1009.1 Modifies width of certain stairways in Group E occupancies	City of Portland	<i>Disapproved 6-25-09</i>		
OSSC10-23	Section 1405.6.2 Modifies seismic requirements specific to anchored masonry veneer	N.W. Concrete Masonry Association	Approved 7-09-09		
OSSC10-24	Section 2104.1 Modifies Certain requirements related to grout fill heights	N.W. Concrete Masonry Association	Approved 7-09-09		Editorial: Staff to coordinate numbering
OSSC10-25	Section 2107.3 Adds language specific to certain anchor bolt installations	N.W. Concrete Masonry Association	Approved 7-09-09		
OSSC10-26	Section 2107.1 Modifies load combination design language	N.W. Concrete Masonry Association	Approved 7-09-09		
OSSC10-27	Section 2108.2 Adds language specific to certain anchor bolt installations	N.W. Concrete Masonry Association	Approved 7-09-09		
OSSC10-28	Section 3202.2 Deletes exceptions to prohibition of encroachments into the public way	City of Portland	<i>Disapproved 6-25-09</i>		
OSSC10-29	Section 3202.2.1 Adds handrail language to projecting steps	City of Portland	<i>Disapproved 6-25-09</i>		
OSSC10-30	Section 3401.4.2 Amends language specific to new and replacement materials	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
OSSC10-31	Section 3405.2.2 Amends allowable materials for certain repairs	SEAO	Tabled 7-22-09		Tabled - At request of BOMA

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
OSSC10-32	Section 3405.2.3 Amends standard certain building rehabilitations are designed to	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
OSSC10-33	Section 3405.3 Modifies Language specific to substantial structural damage to gravity load-carrying components	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
OSSC10-34	Section 3405.4 Amends language specific to less than substantial structural damage	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
OSSC10-35	Table 601 Adds footnote specific to non-load bearing wall fire rating	City of Portland	Tabled 6-25-09		Tabled - 7-22-09 Waiting for further revisions by Proponent.
OSSC10-42	Section 3401.4 amends and adds modifications to compliance under the IEBC	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
OSSC10-43	Chapter 11 ADAAG Figures 39(b) and 39(c) deletes these handrail options	City of Portland	<i>Disapproved</i> 7-22-09		Disapproved in favor of OSSC10-49
OSSC10-44	Section 2308.3.2 Amends braced wall line connections language	Josephine County Building Dept. / Southern Chapter ICC	Approved as Modified by Proponent 6-25-09		
OSSC10-45	Section 2902.2 Amends occupant load calculation for certain fixture uses	City of Portland	Approved as Modified 7-22-09		Modification: The words "and visitors" in section 2902.4 were deleted.

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
NEW AMENDMENT PROPOSALS TO ALTERNATE METHOD #08-05 / IEBC					
IEBC 101.5.4.1	Amends IEBC Section 101.5.4.1 addressing design values	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 101.5.4.2	Amends IEBC Section 101.5.4.2 addressing design values	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 101.5	Amends IEBC Section 101.5 Compliance methods language	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 302.1	Amends IEBC Section 302.1 adding language specific to additions	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 303.1	Amends IEBC Section 303.1 adding language specific to alterations	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 304.1	Amends IEBC Section 304.1 Adding language specific to Repairs	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 307.1	Adds reference back to IBC 3408	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 502.2	Amends Section 502.2 deleting "like materials" language.	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 506.1	Amends Section 506.1, General requirements for structural repair	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 506.2.1	Amends Section 506.2.1, referencing the IBC	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 506.2.2	Amends Section 506.2.2.2 referencing the IBC	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 506.2.3	Amends Section 506.2.2.3 referencing the IBC	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 6.6.2	Amends Section 606.2 specific to roofing and replacement of equipment	SEAO	Tabled 7-22-09		Tabled - At request of BOMA

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
IEBC 606.3	Amends language specific to bracing requirements of unreinforced masonry parapets	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 807.4.2	Amends Section 807.4.2 specific to substantial structural alterations	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 807.4.3	Amends Section 807.4.3 specific to limited structural alterations	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 901.3.1	Amends reference for change of occupancy provisions	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
IEBC 907.3.1	Amends Section 907.3.1 and adds language specific to seismic improvement standards	SEAO	Tabled 7-22-09		Tabled - At request of BOMA
NEW AMENDMENT PROPOSALS (BCD)					
OSSC10-46	Removes maintenance provisions from Section 906 - Portable fire extinguishers	BCD	Approved as Amended 6-25-09		
OSSC10-47	Amends Fuel storage requirements for emergency generators	BCD	Approved 7-22-09		
OSSC10-48	Amends Section 915, Emergency responder radio coverage	BCD	Approved 7-22-09		
OSSC10-49	Chapter 11 handrail coordination with Section 1012	BCD	Approved 7-22-09		

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
EXISTING STATEWIDE ALTERNATE METHODS					
http://www.cbs.state.or.us/external/bcd/programs/structural/alternate_methods.html					
#05-02	Alternate method of construction for Dialysis Facilities	N/A	Retain 7-22-09		Retain - Update code references - 05-02 is markedly more restrictive than 09 IBC "outpatient requirements"
#07-01	Child care in M occupancies	N/A	Retain 7-22-09		Update code references
#08-01	Snow load methodology	N/A	Rescind 7-22-09		<i>Captured in 2009 International Building Code</i>
#08-02	Power actuated fasteners	N/A	Retain 7-22-09		Retain - Based on limitations and design parameter reductions.
#08-03	Screw anchors	N/A	Rescind 7-22-09		<i>Rescind - Based on product availability</i>
#08-04	Adhesive anchors	N/A	Rescind 7-22-09		<i>Rescind - Based on product availability</i>
#08-05	2009 International Existing Building Code	N/A	Retain 7-22-09		Tabled - Structural Provisions - at request of BOMA. Retain: Non-structural provisions.
EXISTING STATEWIDE INTERPRETATIONS					
http://www.cbs.state.or.us/external/bcd/programs/structural_interps_by_date.html					
ESI 08-01	Use of Exterior Insulation and Finish Systems (EIFS)	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 08-02	Agricultural Exemption	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 08-03	Equine Exemption	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 08-04	Sprinklers in F-1 Woodworking facilities	N/A	Retain 7-22-09		Retain - Needed Clarification Update references

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
ESI 07-01	Stories with one exit	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Captured in 2009 International Building Code section 1021</i>
ESI 07-02	Replacement of existing glazing	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 07-03	Stacked decks	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 07-04	Suspended ceiling installation - revised	N/A	Retain 7-22-09		NOTE: Modification necessary to align with approval of proposal #OSSC 10-05
ESI 07-05	Continuity of exit enclosures	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Captured in 2009 IBC Section 1022.1, exception 1</i>
ESI 07-06	Areas of rescue assistance on ground floor	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 07-07	Expansion of malls of type V construction	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 06-01	Landings measurements	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 06-02	Scope of dressing and fitting room provisions	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 06-03	Sprinkler system installations in buildings with	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 06-04	Equine facilities	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 06-05	1109.14.2 Single station alarms / ADA	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 05-01	1103.2.3.2 Detectable warnings at the Vehicular way	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 05-02	503 Establishing allowable area	N/A	Retain 7-22-09		Retain - Needed Clarification

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
ESI 05-03	Special inspections for seismic resistance	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Captured in 2009 IBC</i>
ESI 05-04	Moisture proofing in toilet rooms	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 04-01	302 Classification of fire stations	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 04-02	1702.1 Periodic special inspections	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Captured in 2009 IBC</i>
ESI 03-01	1312.2.1 Averaging of insulation R-value for sloped roof insulation.	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 03-02	1312.2.2 Values obtained from simplified trade off method	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 97-01	Yurts used as recreational structures	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 95-01	Access to swimming pools, hot tubs and spa	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 95-02	Whole building approach	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 95-03	Simplified trade off approach	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 95-04	Disabled access to church baptisteries	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 94-01	Building within a building	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 94-02	Insulation in zero-lot-line walls	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 94-03	Acceptable installation of wall batt insulation	N/A	<i>Rescind 7-22-09</i>		<i>Rescind - Based on adoption of new energy provisions</i>

OREGON STRUCTURAL SPECIALTY CODE AMENDMENTS

Last Updated July 24, 2009

Item Number	Description: Code Section & Topic	Proponent/ Affiliation	Action Taken By Structural Code Committee	Action Taken By Building Codes Structures Board	Comments on Action
ESI 94-04	Acceptable window and door sealing methods	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 94-05	Product approvals and listing agencies	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 94-06	Acceptable fiberglass wall insulation in rim joists	N/A	<i>Rescind</i> 7-22-09		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 94-07	Rational design of structures not using conventional wood framing	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 94-08	Railroad right of way as required yards	N/A	Retain 7-22-09		Retain - Needed Clarification Update references
ESI 93-01	Structures on State, Federal or other property	N/A	Retain 7-22-09		Retain - Needed Clarification
ESI 93-02	Special Inspector certification	N/A	<i>Rescind</i> 7-22-09		<i>Rescind - Captured in 2009 International Building Code Chapter 17</i>
ESI 92-03	One percent decorative or unique architectural glazing	N/A	<i>Rescind</i> 7-22-09		<i>Rescind - Based on adoption of new energy provisions</i>
ESI 92-04	Under floor insulation inspection	N/A	Retain 7-22-09		Retain - Needed Clarification