

**From Stuart Albright, P.E.
Geotechnical Engineer
Existing OSSC amendments –Chapter 18
(Not yet acted upon by OSSC Code Change Committee)**

ITEM	DESCRIPTION	REC.	SUMMARY	SHA RECOMMENDATION
EA07-18	1802.1 & Table 1802.1	Maintain	Existing DOGAMI requirement.	Obsolete but required by ORS
EA07-18	1802.2 Exception	Maintain	Expands scope of exception to include seismic zones D, E & F.	Obsolete but required by ORS
EA07-18	1802.2.7(1)	Maintain	Allows seismic lateral pressures to be based on one-half of the peak horizontal acceleration.	Obsolete but required by ORS
EA07-18	1802.4.2	Maintain	Based on ORS 455.447, Seismic Site Hazard Investigation/Report	Obsolete but required by ORS
EA07-18	1802.7	Maintain	Based on ORS 455.447, Seismic Site Hazard Investigation/Report	Obsolete but required by ORS
EA07-18	1802.8	Maintain	Based on ORS 455.447, Seismic Site Hazard Investigation/Report	Obsolete but required by ORS
EA07-18	1802.9	Maintain	Based on ORS 455.447, Seismic Site Hazard Investigation/Report	Obsolete but required by ORS
EA07-18	1803.7	Maintain	Foundation Drainage. Not captured in 2009 IBC.	I did not catch that this had been dropped. This is a crucial provision. It has likely been dropped since it is covered in the plumbing code but it seems good to have it here.
EA07-18	1805.4.2.7	Maintain	Grounding of foundation rebar. Not captured in 2009 IBC.	No Opinion
EA07-18	1806.1	Delete	Captured in section 1807.2.3 of the 2009 IBC.	Agree
EA07-18	1808.2.8.5 (2)	Maintain	Allows BO to approve other analysis for determining allowable working uplift for pier and pile loads.	I like this provision but it is relatively unused.