

Aeron,

Please share with the committee the proposed language that I have attached. Their full consideration of the suggested language will be appreciated.

**Reason:** It is fundamentally necessary to be able to ventilate each separate attic space independently in order to effectively limit fire and smoke spread.

Respectfully,

Jim Kenworthy

Fire Marshal

Klamath County Fire District No. 1

Ph: (541) 885-2056

**Submitted by Jim Kenworthy, Fire Marshal, Klamath County Fire District No. 1 (2/1/2010)**

**Add a section in an appropriate location that says:**

Where attic spaces are separated into two or more spaces by draft stops or fire rated walls, at least one pathway conforming to the provisions of section 304.9.4 (Submitted by Robert Rice) shall be provided to the solar roof immediately above each attic space. **—END—**