

**304.9.2 Smoke and heat vents. In structures where smoke and heat vents have been installed to comply with the requirements of the IFC Chapter 9 Smoke and Heat Vents and Chapter 23 High Piled Storage a 36 inch wide pathway two and around each vent shall be provided for fire department access, maintenance and testing of these vents.**