



*Working with Oregonians  
to ensure safe building  
construction while  
supporting a positive  
business climate.*

November 29, 2005

**No: 2005 OPSC Section 610.8 and Table 6-5  
2005 Oregon Plumbing Specialty Code**

**Subject:** Water Pipe Sizing For Wells And Pressure Reducing Valves

**Code Section:** Section 610.8 & Table 6-5

**Code Edition:** 2005 Oregon Plumbing Specialty Code

**Date:** November 22, 2005

**Question:** When sizing water supply systems per section 610.8 and Table 6-5, is the pressure tank or pressure reducing valve considered the source of supply?

**Answer:** Yes, the developed length of the water supply piping would be measured beginning at the outlet of the well pressure tank, or at the outlet of the pressure reducing valve if used.

Note: See 2005 ORSC Interpretation Section P2910.6 & Table P2910.2.

**Contact:** Terry Swisher, Chief Plumbing Inspector  
[terry.l.swisher@state.or.us](mailto:terry.l.swisher@state.or.us)  
(503) 373-7488

