

**BUILDING CODES DIVISION RULING ON ACCEPTABILITY OF
MATERIAL, DESIGN OR METHOD OF CONSTRUCTION
RULING NO. 95-13**

Initiated By: DAVID SHEFLIN
MOHAWK METAL COMPANY
P.O. BOX 700
MARCOLA OR 97454

RE: PLUMBING PRODUCT APPROVAL REQUEST—MOHAWK METAL COMPANY.

REQUEST

Approval of steel catch basin.

APPLICABLE CODE SECTIONS OR STANDARDS

1992 Oregon State Plumbing Specialty Code (OSPSC), Chapter 14, Section 1408 (a) through (e).

TECHNICAL AND SCIENTIFIC FACTS

Information submitted by the manufacturer, including engineered drawings, material specifications and HS20-4 AASHTO load calculations, show these products are manufactured in a manner and of a material meeting the standards adopted in the OSPSC.

FINDING

Due to the above technical and scientific facts the Plumbing Board finds the materials and construction of the Mohawk Metal Company's 24-inch × 24-inch × 36-inch catch basin meets the standards prescribed in the OSPSC in quality, strength, effectiveness, durability and safety.

(signed June 16, 1995)

Harry C. Reeder, Chairman
Plumbing Board

Date

RULING

After consideration of the standards and interpretations of the International Association of Plumbing and Mechanical Officials and the findings of the Plumbing Board this ruling is adopted as stated.

(signed June 20, 1995)

Joseph A. Brewer III, Administrator
Building Codes Division

Date