



**2010 ADA UPDATE
December 7, 2011**

**2010 Oregon Structural Specialty Code
Section 907.5.2.3.3, Fire Alarm and Detection Systems
*Effective Date: March 1, 2012***

BACKGROUND:

As part of 2010 ADA update to the 2010 Oregon Structural Specialty Code (OSSC), section 907.5.2.3.3 has been amended to correlate with the 2009 International Building Code accessibility provisions.

This code change has been prepared as insert pages for the 2010 OSSC. Pages are formatted so that when inserted, the amendments will face the page containing the existing code language.

Text formatting; Green text denotes an Oregon amendment.

Contact:

Richard S. Rogers, Structural Program Chief

Richard.Rogers@state.or.us

(503) 378-4472

Steve Judson, P.E., Structural Code Specialist

Steven.W.Judson@state.or.us

(503) 378-4635



[F] 907.5.2.3.3 Groups I-1, R-1 and R-4. Group I-1, R-1 and R-4 *dwelling units* or *sleeping units* shall be provided with a visible alarm notification appliance, activated by both the in-room smoke alarm and the building fire alarm system in accordance with Table 907.5.2.3.3 and the accessibility requirements of ICC A117.1.

[F] TABLE 907.5.2.3.3
VISIBLE ALARMS

NUMBER OF SLEEP UNITS	SLEEPING ACCOMMODATIONS WITH VISIBLE ALARMS
6 to 25	2
26 to 50	4
51 to 75	7
76 to 100	9
101 to 150	12
151 to 200	14
201 to 300	17
301 to 400	20
401 to 500	22
501 to 1,000	5% of total
1,001 and over	50 plus 3 for each 100 over 1,000