



**Mid-Cycle Code Amendment
December 7, 2011**

**2010 Oregon Structural Specialty Code
Chapter 35, Update NFPA Standards
*Effective Date: January 1, 2012***

BACKGROUND:

HISTORY:

National Fire Protection Association (NFPA) produces the National Fire Code regulations that are an integral part of the Oregon Structural Specialty Code (OSSC) and are referenced throughout the code. These standards are updated in cycles similar to the OSSC and as such are constantly evolving with the most current practices and standards for fire and life safety. The NFPA standards referenced in the 2010 OSSC were based on the standards that were available at the time of the 2010 OSSC adoption. Since that time, several of the key NFPA referenced standards have been revised and updated. These revised standards have been adopted as part of the *2010 OSSC Mid-Cycle Code Adoption Process* amending OSSC Chapter 35 as detailed below.

Specific standards being updated to the **2010** Editions:

- NFPA 13, *Installation of Sprinkler Systems*
- NFPA 13D, *Installation of Sprinkler Systems in One- and Two- Family Dwellings and Manufactured Homes*
- NFPA 13R, *Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height*
- NFPA 72, *National Fire Alarm Code*

These code changes have been prepared as insert pages for the 2010 OSSC. Pages are formatted so that when inserted, the amendments will face the page containing the existing code language.

*Text formatting; ~~strike through~~ denotes text that has been deleted,
Underline/bold denotes text that has been added.*

Contact:

Richard S. Rogers, Structural Program Chief

Richard.Rogers@state.or.us

(503) 378-4472

Steve Judson, P.E., Structural Code Specialist

Steven.W.Judson@state.or.us

(503) 378-4635





National Fire Protection Association
 1 Batterymarch Park
 Quincy, MA 02169-7471

Standard reference number		Referenced in code section number
13- 07 10	Installation of Sprinkler Systems	708.2, 903.3.1.1, 903.3.2, 903.3.5.1.1, 903.3.5.2, 904.11, 905.3.4, 907.6.3, 1613.6.3
13D - 07 10	Installation of Sprinkler Systems in One- and Two-family Dwellings and Manufactured Homes	903.3.1.3, 903.3.5.1.1
13R - 07 10	Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height	903.3.1.2, 903.3.5.1.1, 903.3.5.1.2, 903.4
72 - 07 10	National Fire Alarm Code	901.6, 903.4.1, 904.3.5, 907.2, 907.2.5, 907.2.11, 907.2.13.2, 907.3, 907.3.3, 907.3.4, 907.5.2.1.2, 907.5.2.2, 907.6, 907.6.1, 907.6.5, 907.7, 907.7.1, 907.7.2, 911.1.5, 3006.5, 3007.6