

## SECTION 2406 SAFETY GLAZING

**2406.1 Human impact loads.** Individual glazed areas, including glass mirrors, in hazardous locations as defined in Section 2406.3 shall comply with Sections 2406.1.1 through 2406.1.[5] **4.** ||

**2406.1.1 CPSC 16 CFR 1201.** Except as provided in Sections 2406.1.2 through 2406.1.[5] **4,** all glazing shall pass the test requirements of CPSC 16 CFR 1201, listed in Chapter 35. Glazing shall comply with the CPSC 16 CFR, Part 1201 criteria, for Category I or II as indicated in Table 2406.1. ||

~~[2406.1.2 Wired glass. In other than Group E, wired glass installed in fire doors, fire windows and view panels in fire resistant walls shall be permitted to comply with ANSI Z97.1.]~~ <

**2406.1.3 2406.1.2 Plastic glazing.** Plastic glazing shall meet the weathering requirements of ANSI Z97. 1. ||

**2406.1.4 2406.1.3 Glass block.** Glass-block walls shall comply with Section 2101.2.5. ||

**2406.1.5 2406.1.4 Louvered windows and jalousies.** Louvered windows and jalousies shall comply with Section 2403.5. ||